

### CERTIFICATE OF APPROVAL No CF 5294

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

### SYNERGY HARDWARE LIMITED

Unit 2 Heath Mill Business Centre, Heath Mill Road Wombourne, Wolverhampton, WV5 8AP Tel: 01902 893725

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

**CERTIFIED PRODUCT** 

Synergy S100, S150, S300, S500, S600, S700, S800 and S900 Surface Mounted Overhead Door Closers **TECHNICAL SCHEDULE** 

TS 34 - The Contribution Of Controlled Door Closing Devices And Accessories To Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan

**Certification Manager** 



Issued: Re-issued: Valid to: 29<sup>th</sup> September 2015 3<sup>rd</sup> December 2021 2<sup>nd</sup> December 2026

Page 1 of 9





#### SYNERGY OVERHEAD DOOR CLOSERS

1. This approval applies to the Synergy rack and pinion overhead door closer models, but excludes any mechanical hold open variants. The approval applies to the following models and configurations:

		Link-arms			Slide	arms	
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
S100	✓	×	✓	×	×	×	*
S150	✓	×	✓	×	×	×	×
S300	✓	✓	✓	×	×	×	×
S500	✓	✓	✓	×	×	×	*
S600	✓	✓	✓	×	×	×	*
S700	*	×	*	✓	✓	×	✓
S800	✓	×	✓	×	×	×	×
S900	✓	×	✓	*	*	×	×

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

- This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 3. This approval relates to their use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance of up to 120 minutes (Code ITT).

Page 2 of 9 Signed K/002

fol ligg-



#### SYNERGY OVERHEAD DOOR CLOSERS

- 4. The closers are approved on the basis of:
  - i) Initial type testing to BS EN 1154 and BS EN 1634-1
  - ii) An appraisal against TS34
  - iii) Certification of quality management system.
  - iv) Inspection and surveillance of factory production control
  - v) On-going audit testing in accordance with EN 1154 requirements
- 5. This approval is applicable only to the specified closers when mounted in the applications stated later under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
- 6. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
- 7. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
- 8. Timber based doorset shall be installed in accordance with BS 8214.
- 9. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Page 3 of 9 Signed K/002

ful ligg-



#### SYNERGY OVERHEAD DOOR CLOSERS

10. The following table show acceptable doorset types and fire resistance periods:

		Approved Door Type						
Class	IMM	ММ	ITT	ITM	ITC			
FD20	×	×	✓	×	×			
FD30	×	×	✓	×	×			
FD60	×	×	✓	×	×			
FD90	×	×	✓	×	×			
FD120	×	×	✓	×	×			
FD240	×	×	×	×	×			
E 20	×	×	✓	×	×			
EI 20	×	×	✓	×	×			
E 30	×	×	✓	×	×			
EI 30	×	×	✓	×	×			
E 60	×	×	✓	×	×			
EI 60	×	×	✓	×	×			
E 90	×	×	✓	×	×			
EI 90	×	×	✓	×	×			
E 120	×	×	✓	×	×			
EI 120	×	×	✓	×	×			
E 240	×	×	×	×	×			
EI 240	×	×	*	×	×			

#### Kev:

✓

- approved

Not approved

Page 4 of 9 Signed K/002

fol ligg-



#### SYNERGY OVERHEAD DOOR CLOSERS

11. Doors are classified as the following types:

**Code ITT** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

**Code ITM** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames.

**Code ITC** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

**Code MM** - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

**Code IMM** - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals

#### Scope of Approval:

- The closers may not be fitted to timber doorsets without perimeter intumescent fire seals to the frame rebate or door edge.
- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body
- Standard arm brackets only are approved.

Pol ligg-

· Hold open option is not approved.

Page 5 of 9 Signed K/002

29<sup>th</sup> September 2015 3<sup>rd</sup> December 2021 2<sup>nd</sup> December 2026

Issued:

Valid to:

Re-issued:



#### SYNERGY OVERHEAD DOOR CLOSERS

#### Scope of Approval – Cont'd:

• The following functions are supported by this certification:

Closer Ref.	Application	Latch Control	Backcheck	Delayed- Action
S100	Projecting arm (Fig. 1)	Yes	No	No
S100	Parallel arm (Fig. 6)	No	No	No
S150	Projecting arm (Fig. 1)	Yes	No	No
S150	Parallel arm (Fig. 6)	No	No	No
S300	Projecting arm (Fig. 1)	Yes	Yes	No
S300	Projecting arm (Fig. 61) transom mounted	Yes	No	No
S300	Parallel arm (Fig. 6)	No	No	No
S500	Projecting arm (Fig. 1)	Yes	Yes	No
S500	Parallel arm (Fig. 6)	No	No	No
S500	Projecting arm (Fig. 61) transom mounted	Yes	No	No
S600	Projecting arm (Fig. 1) & Projecting arm (Fig. 61) transom mounted	Yes	Yes	No
S600	Parallel arm (Fig. 6)	No	Yes	No
S700	All approved configurations	Yes	Yes	No
S800	Projecting arm (Fig. 1)	Yes	Yes	No
S800	Parallel arm (Fig. 6)	No	Yes	No
S900	Projecting arm (Fig. 1)	Yes	Yes	No
S900	Parallel arm (Fig. 6)	Yes	Yes	No

#### **EN1154 Classification codes:**

S100 and S150 in Figure 1 projecting arm application:

S100 and S150 in Figure 6 parallel arm application:

3 8	3 1	1	3
-----	-----	---	---

Page 6 of 9 Signed K/002



#### SYNERGY OVERHEAD DOOR CLOSERS

#### **EN1154 Classification codes (continued):**

S300 in Figure 1 projecting arm & projecting arm (Fig. 61) transom mounted application:

3	8	4 2	1	1	3
---	---	-----	---	---	---

S300 in Figure 6 parallel arm application:

3 8	3 1	1	3
-----	-----	---	---

S500 in Figure 1 projecting arm and Figure 6 parallel arm applications:

3 8	4 2	1	1	4
-----	--------	---	---	---

S500 in projecting arm (Fig. 61) transom mounted application:

|--|

S600 in Figure 1 projecting arm & projecting arm (Fig. 61) transom mounted application:

4	8	4 2	1	1	3
---	---	-----	---	---	---

S600 in Figure 6 parallel arm application:

3 8	4 3	1	1	3
-----	-----	---	---	---

Page 7 of 9 Signed K/002

fol egg-



#### SYNERGY OVERHEAD DOOR CLOSERS

#### **EN1154 Classification codes (continued):**

S700 in slide arm body door mounted on pull face and transom mounted on pull face applications:

4 8	4 2	1	1	3
-----	-----	---	---	---

S700 in slide arm body transom mounted on push face applications:

3	8	4 2	1	1	3
---	---	--------	---	---	---

S800 in Figure 1 projecting arm application:

4 8	5 2	1	1	4
-----	--------	---	---	---

S800 in Figure 6 parallel arm application:

3	8	4 3	1	1	4
---	---	-----	---	---	---

S900 in Figure 1 projecting arm applications:

4	8	6	1	1	3
---	---	---	---	---	---

S900 in Figure 6 parallel arm applications:

4	8	5 3	1	1	3
		3			

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Page 8 of 9 Signed K/002



#### SYNERGY OVERHEAD DOOR CLOSERS

#### **Further Information**

Further information regarding the details contained in this certificate may be obtained from Synergy Hardware Limited (Tel: 01902 893725).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 9 of 9 Signed K/002

fol agg-